IC ENGINE OPERATING LOG

Equip #	091089	**Maximum Permitted Annual Operating Hours**	200	**Maximum M&T Annual Hours**	50
Permit #	F96434	**Facility ID**	72512	**Maximum Monthly M&T Hours (if limited)**	
Site Location Name	Bertha Peak				

Date	Operator	Hr Meter Start	Hr Meter End	M&T Hours	E. P Hours	Reason for use
1.1.24	SBCo.	861.3	-	-	-	Beginning Hours of 2024
2.6.24-2.14.24	SBCo.	861.3	1063.7	-	202.4	Power Outage
3.9.24	SBCo.	1063.7	1065.6	-	1.9	Power Outage

Total Annual Hours	204.3	**Annual M&T hrs.**	0	**Annual E.P hrs.**	204.3

M&T = Maintenance & Testing **E.P. = Generator operation to provide emergency power**

Technicians notify your Supervisor if the hours of operation are within 25 hours of the Maximum Annual Permitted Hours or Maximum Annual M&T hours. Failure to do this could result in fines and penalties from the AQMD if the hours are exceeded prior to having a Request for Variance filed.