

SAN BERN. CO, OFF OF MGMT SERV (COMM DIV)

Hearing Board Case # 6070-12
Facility ID No. 72512 (Bertha Peak)

Interim Variance Conditions

March 14, 2024

1. Petitioner shall limit the operation of the Internal Combustion Engine (“ICE”), as described in Permit to Operate (“PO”) No. F96434, to emergency usage, and the ICE shall operate no more than 1.0 hour per month total for maintenance and testing time.
2. Petitioner shall maintain a monthly operating log for the emergency ICE and shall send the records to the South Coast AQMD by email to AQ Inspector Alicia Green (agreen@aqmd.gov) on the first Tuesday of each month beginning March 5, 2024. The operating log shall list all engine operations in the following areas:
 - a. Date and hours of emergency operation, and specify the cause of the emergency;
 - b. Date and hours of maintenance and testing operations; and
 - c. Date and hours of any other non-emergency operation.
3. Petitioner shall calculate, record, and report all excess emissions during the variance period to the Clerk of the Board and AQ Inspector Alicia Green by _____.
4. Pursuant to South Coast AQMD Rule 303(p), all fees for this interim variance shall be waived.