

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28

**BEFORE THE HEARING BOARD OF THE
SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT**

In the Matter of
UNITED STATES NAVY,
Facility ID# 146536

Case No. 4518-10

STIPULATION

District Rules 203(b) and 3002(c)

Hearing Date: August 29, 2024
Time: 9:30 a.m.
Place: 21865 Copley Drive
Diamond Bar, CA 91765-0940

We, the undersigned parties, hereby agree and stipulate as follows:

1. The Petitioner and the District agree to have this matter placed on the Hearing Board’s Consent Calendar on August 29, 2024.
2. The Petitioner seeks an interim variance from the provisions of Rules 203(b) and 3002(c)(1) {from Section D, Condition No. C1 .1 of Title V Facility P/O No. 800263} of the South Coast Air Quality Management District Rules and Regulations.
3. The parties agree to have the Declaration of Frank Williamson, Environmental Protection Specialist for the Petitioner, admitted into evidence regarding this matter.
4. The parties agree to incorporate all prior evidence and testimony from the ex parte emergency variance matter that resulted in the minute order dated August 2, 2024.
5. In response to the District’s request, Petitioner has revised its response to question no. 19 in the Petition addressing excess emissions in the Declaration of Frank Williamson to

1 reflect (1) actual emission factors provided in the original permit applications for D21 and D200
2 and (2) a 100% fuel load. Using these inputs, Excess Emissions are estimated to be:

3 Source	Daily Consumption(1000 Gal)	CO lb/day	NOx 1b/day	PM10 lb/day	ROG 1b/day
4 D 21	.6326	63.6	292.47	21.19	23.72
D200	.2084	72.52	45.8	3.24	8.53

5 The Parties agree to calculate actual Excess Emissions using fuel usage records consistent with
6 District Rules.

7 6. The parties have agreed on a set of (Proposed) Findings and Decision and a
8 (Proposed) Order (which includes proposed conditions), which is submitted concurrently with
9 this Stipulation.

10 7. The District does not oppose the Petitioner's request for the granting of a variance
11 for the Petitioner.

12 8. The variance sought by the Petitioner is not expected to result in a violation of
13 Health and Safety Code Section 41700.

14 **SO STIPULATED**

15 Dated: August_27, 2024


UNITED STATES NAVY

17 **SILVERSTEIN.DAV** Digitally signed by
18 **ID.E.1230503067** SILVERSTEIN.DAVID.E.123050306
Date: 2024.08.27 12:19:16 -07'00'

19 By: _____
20 DAVID SILVERSTEIN
Assistant Counsel, Navy OGC

21 Dated: August_27, 2024

SOUTH COAST AIR QUALITY MANAGEMENT
22 DISTRICT

23
24
25 By: 
26 _____
27 KARIN MANWARING
Senior Deputy District Counsel

28