

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28

BEFORE THE HEARING BOARD OF THE  
SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT

**In the Matter of**

WALNUT CREEK ENERGY LLC  
[Facility ID No. 146536],

Petitioner,

v.

SOUTH COAST AIR QUALITY  
MANAGEMENT DISTRICT.

Respondent.

Case No. 6230-2

**DECLARATION OF GEORGE  
PIANTKA RE REGULAR VARIANCE  
PETITION; FILED IN SUPPORT OF  
CONSENT CALENDAR**

Hearing Date: May 21, 2024  
Time: 9:30 a.m.  
Place: South Coast Air Quality  
Management District  
21865 Copley Drive  
Diamond Bar, CA 91765

I, George Piantka, declare:

1. I am the Senior Director for NRG Energy, which operates Walnut Creek Energy (“Facility”). If called as a witness, I could testify to the following based on personal knowledge.

2. I am familiar with and have reviewed the petition filed in Case no 6230-2, and I am familiar with the issues presented in the petition related to the start-up nitrogen oxides (NOx) mass emission requirements of the Facility’s permit, including Permit Condition A195.7 on Facility Permit No. 146536 (Revision no. 9) (the revised “Title V Permit”).

3. For the past 9 years I have served as the Senior Director of Regulatory Environmental Services at NRG Energy, which operates Walnut Creek Energy, a 500 MW natural gas-fired power plant powered by five (5) GE LMS100 simple cycle gas turbines. On January 31, 2024, the Facility was issued a Permit to Construct and Temporary Permit to Operate (PTC/TPTO) for an increase of the maximum heat input rate that will allow increased electrical generation to

1 California's power grid that would help address regional generation needs and improve system  
2 grid reliability.

3 4. The PTC/TPTO contained a new Permit Condition A195.7 that applies to Gas Turbine  
4 Units 1-5 (Devices D1, D7, D13, D19, D25). This condition includes, for the first time, a new  
5 NOx mass emission limit for start-up operations that takes effect 90 days after the completion of  
6 recommissioning for each unit following replacement of the selective catalytic reduction (SCR)  
7 catalyst. The new mass emission start-up limit for NOx, as stated in A195.7, does not represent a  
8 rule compliance requirement or Best Available Control Technology (BACT) standard. This limit  
9 was added to the Title V permit in the January 31, 2024 PTC/TPTO to enforce NOx emission  
10 estimates for start-up operations assumed by the South Coast AQMD engineering staff during  
11 initial facility permitting and used for emission calculation purposes.

12 5. The SCR catalysts for Units 1-5 were installed between February 18, 2024, and April  
13 28, 2024. Following the start-up of the first unit, Unit 2, on February 27, 2024, after SCR  
14 installation, the Facility reviewed continuous emissions monitoring system (CEMS) data and  
15 determined that the NOx start-up mass emission limit identified in A195.7 could not be achieved.  
16 Following start-up of Unit 3, a similar review of CEMS data also determined that compliance with  
17 the new NOx startup limit could not be achieved. The Facility along with its consultant, Yorke  
18 Engineering, compared the new start-up limit to other similar electrical generating units permitted  
19 in the South Coast AQMD and found this limit to be lower and inconsistent with those permits. In  
20 consultation with South Coast AQMD permitting staff, it was agreed that an increase in the NOx  
21 start-up limit would be appropriate but that the change would have to be permitted through a  
22 separate permitting action from the PTC/TPTO that was issued on January 31, 2024.

23 6. Unit 2 will become subject to the new start-up mass emission limit for NOx on July 15,  
24 2024, followed by Unit 3 on July 22, 2024, and then Units 1, 4, and 5 by September 5-25, 2024,  
25 respectively. The Facility plans to submit a permit application to modify the NOx start-up limit  
26 shown in Permit Condition A195.7 within 60 days of the variance hearing.

27 7. The team at the Facility, including myself, have worked diligently to determine the  
28 appropriate course of action in light of these facts.

1           8. Excess emission will be mitigated through compliance with existing natural gas  
2 throughput usage limits, and compliance with all other Title V mass emission limits. The Facility  
3 is subject to a permitted natural gas fuel usage limit of no more than 20.7 MM cubic feet per day  
4 per turbine. The Facility will comply with this limit throughout the variance period, and not  
5 exceed any existing permitted mass emission limit, other than the NOx start-up limit for which  
6 relief is requested. The daily natural gas usage limit developed during recent permitting actions to  
7 enforce potential to emit emissions under new source review based on operating 24 hours per day  
8 at maximum turbine load (i.e., 100% fuel heat input rate). By committing to operate below the  
9 daily natural gas fuel limit, the Facility will ensure that actual emissions will remain less than  
10 permitted levels for all pollutants, including NOx. Moreover, the Facility will monitor NOx  
11 emissions during the variance period using a certified continuous emission monitoring system  
12 (CEMS) for gas turbine Units 1-5.

13           I declare under penalty of perjury under the laws of the State of California that the  
14 foregoing is true and correct. Executed this day of May 21, 2024 at City of Industry, California.

15  
16  
17  
18  


19  
20  
21  
22  
23  
24  
25  
26  
27  
28  

---

GEORGE PIANTKA