



The West Valley Water District collected Chromium 6 samples from all our sources between December 2002 and February 2003 in accordance with US EPA Unregulated Contaminant Monitoring Rule. The results ranged from non-detect to 4 parts per billion (ppb).

The District also collects Total Chromium Samples from all our water sources every three (3) years. Currently, District Water Quality Staff are collecting these samples for 2008. Chromium 6 is counted as a part of the Total Chromium results.

On June 23, 2008 the District collected seven (7) Total Chromium samples and one (1) Chromium 6 due to customer concerns. These samples were taken at dedicated District Sample locations near the Riverside Cement Plant. The results for Total Chromium ranged from non-detect to 2.4 parts per billion (ppb). The Chromium 6 sample result was 1.6 parts per billion (ppb) taken at Hall and Kinningham. Chromium 6 is a part of the Total Chromium sample result.

Chromium 6 is not a regulated contaminant in California at this time. California does not anticipate setting a maximum contaminant level (MCL) until 2009. The District is not required to sample for Chromium 6 until the MCL is set.

The District has no wells located near the Riverside Cement Plant, all our water is imported into this area.

Lab Sheets

Units- Ug/L = parts per billion (ppb)

MCL= maximum contaminant level

ND= non detect

US EPA = United States Environmental Protection Agency

For additional information or questions, please feel free to contact Ken Sikorski at (909) 875-1322 or ksikorski@wwvd.org

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

Client: West Valley Water District
Project ID: Special Samples
Distribution Total Chrome

Sampled: 06/23/08
Received: 06/23/08

Analyte	Method	Units	Sample Result	MCL Level	Exceeds MCL	Trigger Level	Exceeds Trigger	Data Qualifiers
Chromium								
CRF0843-01 (11821 Cricket - Water)	EPA 200.8	ug/l	2.0	50	<input type="checkbox"/>		<input type="checkbox"/>	
CRF0843-02 (Halt and Kinningham - Water)	EPA 200.8	ug/l	2.1	50	<input type="checkbox"/>		<input type="checkbox"/>	
CRF0843-03 (10305 Castelland - Water)	EPA 200.8	ug/l	ND	50	<input type="checkbox"/>		<input type="checkbox"/>	
CRF0843-04 (11088 Spruce - Water)	EPA 200.8	ug/l	2.4	50	<input type="checkbox"/>		<input type="checkbox"/>	
CRF0843-05 (Lanch and Meadow Lane - Water)	EPA 200.8	ug/l	2.2	50	<input type="checkbox"/>		<input type="checkbox"/>	
CRF0843-06 (11868 Pepper - Water)	EPA 200.8	ug/l	2.3	50	<input type="checkbox"/>		<input type="checkbox"/>	
CRF0843-07 (18791 14St. - Water)	EPA 200.8	ug/l	2.2	50	<input type="checkbox"/>		<input type="checkbox"/>	
Chromium VI								
CRF0843-02 (Halt and Kinningham - Water)	EPA 218.6	ug/l	1.6		<input type="checkbox"/>		<input type="checkbox"/>	

Analysis Report: Lab Job M30184

Client: Oliver P Roemer Water Filt Fac
 c/o West San Bernardino Co WD.
 P.O. Box 920
 Rialto, CA 92377-0920

Project No.:
 Contact: Ken Sikorski
 Phone: (909)875-1804

Project:

Sampled By: ERNIE
 Date Sampled: 01/08/03 09:30:00
 Date Received: 01/08/03 12:20:00
 Date Started: 01/09/03
 Date Completed: 01/14/03
 Date Reported: 03/02/03 17:23:43

Lab Contact:
 Job No.:
 COC Log No.:
 Lab ID No.: M30184-1A
 Batch No.:
 Instrument ID: VAR
 Analyst ID: LAB4STAFF
 Matrix: WATER

Sample: PLANT EFFLUENT

Surface Water

Analyte	CAS No.	Results	DLR	Method
Arsenic (As)	7440-38-2	ND	2.0	SM 3113-B
Boron (B)	7440-42-8	ND	100	EPA 200.7
Chloride (Cl)	N/A	42	1.0	EPA 300.0
Chromium (+6)	N/A	ND	1.0	EPA 218.6
Perchlorate (ClO4)	N/A	ND	4.0	EPA 314.0
Total Alkalinity (as CaCO3)	N/A	130	1.0	SM 2320-B
Total Organic Carbon	N/A	ND	0.50	SM 5310-B
Vanadium (V)	7440-62-2	3.6	3.0	EPA 200.9

ND = Not detected at or above indicated DLR; Detection Limit for Reporting

Manager: _____

Director: _____

Analysis Report: Lab Job M30228

Client: West San Bernardino County WD
P.O. Box 920
Rialto, CA 92376-0920

Project No.:
Contact: Ken Sikorski
Phone: (909)875-1804

Project:

Sampled By: SPIK
Date Sampled: 01/10/03 11:30:00
Date Received: 01/10/03 14:50:00
Date Started: 01/10/03
Date Completed: 01/14/03
Date Reported: 03/02/03 17:09:17

Lab Contact:
Job No.:
COC Log No.:
Lab ID No.: M30228-5A
Batch No.:
Instrument ID: VAR
Analyst ID: ORGSTAFF
Matrix: WATER

Sample: WELL 1 *Lytle Basin*

Analyte		CAS No.	Results	DLR	Method
Boron (B)	ug/L	7440-42-8	ND	100	EPA 200.7
Chromium (+6)	ug/L	N/A	1.0	1.0	EPA 218.6
Perchlorate (ClO4)	ug/L	N/A	ND	4.0	EPA 314.0
Vanadium (V)	ug/L	7440-62-2	4.5	3.0	EPA 200.9

ND = Not detected at or above indicated DLR; Detection Limit for Reporting

Zones

Manager: _____

Director: _____

Analysis Report: Lab Job M30228

Client: West San Bernardino County WD
 P.O. Box 920
 Rialto, CA 92376-0920

Project No.:
 Contact: Ken Sikorski
 Phone: (909)875-1804

Project:

Sampled By: SPIK
 Date Sampled: 01/10/03 12:30:00
 Date Received: 01/10/03 14:50:00
 Date Started: 01/10/03
 Date Completed: 01/14/03
 Date Reported: 03/02/03 17:09:17

Lab Contact:
 Job No.:
 COC Log No.:
 Lab ID No.: M30228-6A
 Batch No.:
 Instrument ID: VAR
 Analyst ID: ORGSTAFF
 Matrix: WATER

Sample: WELL 2

Lytle Basin

Analyte		CAS No.	Results	DLR	Method
Boron (B)	ug/L	7440-42-8	ND	100	EPA 200.7
Chromium (+6)	ug/L	N/A	ND	1.0	EPA 218.6
Perchlorate (ClO4)	ug/L	N/A	ND	4.0	EPA 314.0
Source Temperature	C	N/A	15.6	0.0	
Vanadium (V)	ug/L	7440-62-2	7.4	3.0	EPA 200.9
Apparent Color (Unfiltered)	Units	N/A	ND	3.0	SM 2120B
Odor Threshold at 60 C	TON	N/A	1	1.0	EPA 140.1
Lab Turbidity	NTU	N/A	0.1	0.10	EPA 180.1

ND = Not detected at or above indicated DLR; Detection Limit for Reporting

Manager: _____

Director: _____

Analysis Report: Lab Job M30228

Client: West San Bernardino County WD
 P.O. Box 920
 Rialto, CA 92376-0920

Project No.:
 Contact: Ken Sikorski
 Phone: (909)875-1804

Project:

Sampled By: SPIK
 Date Sampled: 01/10/03 13:00:00
 Date Received: 01/10/03 14:50:00
 Date Started: 01/10/03
 Date Completed: 01/14/03
 Date Reported: 03/02/03 17:09:17

Lab Contact:
 Job No.:
 COC Log No.:
 Lab ID No.: M30228-7A
 Batch No.:
 Instrument ID: VAR
 Analyst ID: ORGSTAFF
 Matrix: WATER

Sample: WELL 5A

Lytle Basin

Analyte		CAS No.	Results	DLR	Method
Boron (B)	ug/L	7440-42-8	ND	100	EPA 200.7
Chromium (+6)	ug/L	N/A	1.0	1.0	EPA 218.6
Perchlorate (ClO4)	ug/L	N/A	ND	4.0	EPA 314.0
Source Temperature	C	N/A	16.7	0.0	
Vanadium (V)	ug/L	7440-62-2	5.8	3.0	EPA 200.9
Apparent Color (Unfiltered)	Units	N/A	ND	3.0	SM 2120B
Odor Threshold at 60 C	TON	N/A	1	1.0	EPA 140.1
Lab Turbidity	NTU	N/A	0.2	0.10	EPA 180.1

ND = Not detected at or above indicated DLR; Detection Limit for Reporting

Manager: _____

Director: _____

Analysis Report: Lab Job M30225

Client: West San Bernardino County WD
 P.O. Box 920
 Rialto, CA 92376-0920

Project No.:
 Contact: Ken Sikorski
 Phone: (909)875-1804

Project:

Sampled By: T SPIK
 Date Sampled: 01/09/03 14:30:00
 Date Received: 01/09/03 16:05:00
 Date Started: 01/09/03
 Date Completed: 01/14/03
 Date Reported: 03/02/03 17:05:35

Lab Contact:
 Job No.:
 COC Log No.:
 Lab ID No.: M30225-7A
 Batch No.:
 Instrument ID: VAR
 Analyst ID: ORGSTAFF
 Matrix: WATER

Sample: WELL 7

Lytle Basin

Analyte		CAS No.	Results	DLR	Method
Arsenic (As)	ug/L	7440-38-2	5.5	2.0	SM 3113-B
Boron (B)	ug/L	7440-42-8	ND	100	EPA 200.7
Chromium (+6)	ug/L	N/A	1.7	1.0	EPA 218.6
Perchlorate (ClO4)	ug/L	N/A	ND	4.0	EPA 314.0
Source Temperature	C	N/A	18.9	0.0	
Vanadium (V)	ug/L	7440-62-2	5.4	3.0	EPA 200.9
Apparent Color (Unfiltered)	Units	N/A	ND	3.0	SM 2120B
Odor Threshold at 60 C	TON	N/A	1	1.0	EPA 140.1
Lab Turbidity	NTU	N/A	0.3	0.10	EPA 180.1

ND = Not detected at or above indicated DLR; Detection Limit for Reporting

Manager: _____

Director: _____

Analysis Report: Lab Job M2A957

Client: West San Bernardino County WD
 P.O. Box 920
 Rialto, CA 92376-0920

Project No.:
 Contact: Ken Sikorski
 Phone: (909)875-1804

Project:

Sampled By: T SPIK
 Date Sampled: 12/20/02 11:45:00
 Date Received: 12/20/02 14:00:00
 Date Started: 12/20/02
 Date Completed: 01/09/03
 Date Reported: 03/02/03 17:28:44

Lab Contact:
 Job No.:
 COC Log No.:
 Lab ID No.: M2A957-6A
 Batch No.:
 Instrument ID: VAR
 Analyst ID: ORGSTAFF
 Matrix: WATER

Sample: WELL 11

Rialto Basin

Analyte		CAS No.	Results	DLR	Method
Arsenic (As)	ug/L	7440-38-2	ND	2.0	SM 3113-B
Boron (B)	ug/L	7440-42-8	ND	100	EPA 200.7
Chromium (+6)	ug/L	N/A	1.0	1.0	EPA 218.6
Nitrite as N (NO2-N)	ug/L	N/A	ND	400	EPA 300.0
Perchlorate (ClO4)	ug/L	N/A	ND	4.0	EPA 314.0
Source Temperature	C	N/A	17.8	0.0	
Vanadium (V)	ug/L	7440-62-2	4.1	3.0	EPA 200.9
Apparent Color (Unfiltered)	Units	N/A	ND	3.0	SM 2120B
Odor Threshold at 60 C	TON	N/A	1	1.0	EPA 140.1
Lab Turbidity	NTU	N/A	0.5	0.10	EPA 180.1

ND = Not detected at or above indicated DLR; Detection Limit for Reporting

Manager: _____

Director: _____

Analysis Report: Lab Job M30225

Client: West San Bernardino County WD
P.O. Box 920
Rialto, CA 92376-0920

Project No.:
Contact: Ken Sikorski
Phone: (909)875-1804

Project:

Sampled By: T SPIK
Date Sampled: 01/09/03 13:40:00
Date Received: 01/09/03 16:05:00
Date Started: 01/09/03
Date Completed: 01/14/03
Date Reported: 03/02/03 17:05:35

Lab Contact:
Job No.:
COC Log No.:
Lab ID No.: M30225-2A
Batch No.:
Instrument ID: VAR
Analyst ID: ORGSTAFF
Matrix: WATER

Sample: WELL 15 Buckhill Basin

Analyte		CAS No.	Results	DLR	Method
Boron (B)	ug/L	7440-42-8	ND	100	EPA 200.7
Chromium (+6)	ug/L	N/A	1.6	1.0	EPA 218.6
Perchlorate (ClO4)	ug/L	N/A	ND	4.0	EPA 314.0
Source Temperature	C	N/A	16.7	0.0	
Vanadium (V)	ug/L	7440-62-2	3.9	3.0	EPA 200.9
Apparent Color (Unfiltered)	Units	N/A	ND	3.0	SM 2120B
Odor Threshold at 60 C	TON	N/A	1	1.0	EPA 140.1
Lab Turbidity	NTU	N/A	0.1	0.10	EPA 180.1

ND = Not detected at or above indicated DLR; Detection Limit for Reporting

Manager: _____

Director: _____

Analysis Report: Lab Job M30225

Client: West San Bernardino County WD
 P.O. Box 920
 Rialto, CA 92376-0920

Project No.:
 Contact: Ken Sikorski
 Phone: (909)875-1804

Project:

Sampled By: T SPIK
 Date Sampled: 01/09/03 15:00:00
 Date Received: 01/09/03 16:05:00
 Date Started: 01/09/03
 Date Completed: 01/14/03
 Date Reported: 03/02/03 17:05:35

Lab Contact:
 Job No.:
 COC Log No.:
 Lab ID No.: M30225-5A
 Batch No.:
 Instrument ID: VAR
 Analyst ID: ORGSTAFF
 Matrix: WATER

Sample: WELL 16

Rialto Basin

Analyte		CAS No.	Results	DLR	Method
Boron (B)	ug/L	7440-42-8	ND	100	EPA 200.7
Chromium (+6)	ug/L	N/A	1.0	1.0	EPA 218.6
Perchlorate (ClO4)	ug/L	N/A	ND	4.0	EPA 314.0
Source Temperature	C	N/A	18.9	0.0	
Vanadium (V)	ug/L	7440-62-2	7.8	3.0	EPA 200.9
Apparent Color (Unfiltered)	Units	N/A	ND	3.0	SM 2120B
Odor Threshold at 60 C	TON	N/A	1	1.0	EPA 140.1
Lab Turbidity	NTU	N/A	0.6	0.10	EPA 180.1

ND = Not detected at or above indicated DLR; Detection Limit for Reporting

Manager: _____

Director: _____

Analysis Report: Lab Job M30225

Client: West San Bernardino County WD
P.O. Box 920
Rialto, CA 92376-0920

Project No.:
Contact: Ken Sikorski
Phone: (909)875-1804

Project:

Sampled By: T SPIK
Date Sampled: 01/09/03 00:00:00
Date Received: 01/09/03 16:05:00
Date Started: 01/09/03
Date Completed: 01/14/03
Date Reported: 03/02/03 17:05:35

Lab Contact:
Job No.:
COC Log No.:
Lab ID No.: M30225-9A
Batch No.:
Instrument ID: VAR
Analyst ID: ORGSTAFF
Matrix: WATER

Sample: WELL 18A North Riverside

Analyte	Units	CAS No.	Results	DLR	Method
Apparent Color (Unfiltered)	Units	N/A	ND	3.0	SM 2120-B
Boron (B)	ug/L	7440-42-8	ND	100	EPA 200.7
Chromium (+6)	ug/L	N/A	2.3	1.0	EPA 218.6
Nitrate (NO3)	mg/L	N/A	30	2.0	EPA 300.0
Perchlorate (ClO4)	ug/L	N/A	ND	4.0	EPA 314.0
Vanadium (V)	ug/L	7440-62-2	6.6	3.0	EPA 200.9
Odor Threshold at 60 C	TON	N/A	1	1.0	EPA 140.1
Lab Turbidity	NTU	N/A	0.9	0.10	EPA 180.1

ND = Not detected at or above indicated DLR; Detection Limit for Reporting

Manager: _____

Director: _____

Analysis Report: Lab Job M30228

Client: West San Bernardino County WD
P.O. Box 920
Rialto, CA 92376-0920

Project No.:
Contact: Ken Sikorski
Phone: (909)875-1804

Project:

Sampled By: SPIK
Date Sampled: ~~01/10/03~~ 01/10/03 10:00:00
Date Received: 01/10/03 14:50:00
Date Started: 01/10/03
Date Completed: 01/14/03
Date Reported: 03/02/03 17:09:17

Lab Contact:
Job No.:
COC Log No.:
Lab ID No.: M30228-1A
Batch No.:
Instrument ID: VAR
Analyst ID: ORGSTAFF
Matrix: WATER

Sample: WELL 23A

Rialto Basin

Analyte	CAS No.	Results	DLR	Method
Boron (B)	7440-42-8	ND	100	EPA 200.7
Chromium (+6)	N/A	ND	1.0	EPA 218.6
Perchlorate (ClO4)	N/A	ND	4.0	EPA 314.0
Vanadium (V)	7440-62-2	7.8	3.0	EPA 200.9

ND = Not detected at or above indicated DLR; Detection Limit for Reporting

Manager: _____

Director: _____

Analysis Report: Lab Job M31551

Client: West San Bernardino County WD
 P.O. Box 920
 Rialto, CA 92376-0920

Project No.:
 Contact: Ken Sikorski
 Phone: (909)875-1804

Project:

Sampled By: T SPIK
 Date Sampled: 02/25/03 11:00:00
 Date Received: 02/25/03 11:30:00
 Date Started: 02/25/03
 Date Completed: 03/07/03
 Date Reported: 03/30/03 19:32:07

Lab Contact:
 Job No.:
 COC Log No.:
 Lab ID No.: M31551-1A
 Batch No.:
 Instrument ID: VAR
 Analyst ID: ORGSTAFF
 Matrix: WATER

Sample: WELL 24

Rialto Basin

Analyte		CAS No.	Results	DLR	Method
Arsenic (As)	ug/L	7440-38-2	ND	2.0	SM 3113-B
Boron (B)	ug/L	7440-42-8	ND	100	EPA 200.7
Chromium (+6)	ug/L	N/A	4.0	1.0	EPA 218.6
Perchlorate (ClO4)	ug/L	N/A	ND	4.0	EPA 314.0
Vanadium (V)	ug/L	7440-62-2	ND	3.0	EPA 200.9

ND = Not detected at or above indicated DLR; Detection Limit for Reporting

Manager: _____

Director: _____

Analysis Report: Lab Job M30225

Client: West San Bernardino County WD
 P.O. Box 920
 Rialto, CA 92376-0920

Project No.:
 Contact: Ken Sikorski
 Phone: (909)875-1804

Project:

Sampled By: T SPIK
 Date Sampled: 01/09/03 14:00:00
 Date Received: 01/09/03 16:05:00
 Date Started: 01/09/03
 Date Completed: 01/14/03
 Date Reported: 03/02/03 17:05:35

Lab Contact:
 Job No.:
 COC Log No.:
 Lab ID No.: M30225-6A
 Batch No.:
 Instrument ID: VAR
 Analyst ID: ORGSTAFF
 Matrix: WATER

Sample: WELL 33

Rialto Basin

Analyte		CAS No.	Results	DLR	Method
Boron (B)	ug/L	7440-42-8	ND	100	EPA 200.7
Chromium (+6)	ug/L	N/A	1.2	1.0	EPA 218.6
Perchlorate (ClO4)	ug/L	N/A	ND	4.0	EPA 314.0
Source Temperature	C	N/A	18.9	0.0	
Vanadium (V)	ug/L	7440-62-2	6.7	3.0	EPA 200.9
Apparent Color (Unfiltered)	Units	N/A	ND	3.0	SM 2120B
Odor Threshold at 60 C	TON	N/A	1	1.0	EPA 140.1
Lab Turbidity	NTU	N/A	0.4	0.10	EPA 180.1

ND = Not detected at or above indicated DLR; Detection Limit for Reporting

Manager: _____

Director: _____

Analysis Report: Lab Job M30225

Client: West San Bernardino County WD
 P.O. Box 920
 Rialto, CA 92376-0920

Project No.:
 Contact: Ken Sikorski
 Phone: (909)875-1804

Project:

Sampled By: T SPIK
 Date Sampled: 01/09/03 14:40:00
 Date Received: 01/09/03 16:05:00
 Date Started: 01/09/03
 Date Completed: 01/14/03
 Date Reported: 03/02/03 17:05:35

Lab Contact:
 Job No.:
 COC Log No.:
 Lab ID No.: M30225-3A
 Batch No.:
 Instrument ID: VAR
 Analyst ID: ORGSTAFF
 Matrix: WATER

Sample: WELL 30

Bunker Hill Basin

Analyte		CAS No.	Results	DLR	Method
Boron (B)	ug/L	7440-42-8	ND	100	EPA 200.7
Chromium (+6)	ug/L	N/A	ND	1.0	EPA 218.6
Perchlorate (ClO4)	ug/L	N/A	ND	4.0	EPA 314.0
Source Temperature	C	N/A	16.7	0.0	
Vanadium (V)	ug/L	7440-62-2	3.0	3.0	EPA 200.9
Apparent Color (Unfiltered)	Units	N/A	ND	3.0	SM 2120B
Odor Threshold at 60 C	TON	N/A	1	1.0	EPA 140.1
Lab Turbidity	NTU	N/A	2.3	0.10	EPA 180.1

ND = Not detected at or above indicated DLR; Detection Limit for Reporting

Manager: _____

Director: _____

Analysis Report: Lab Job M31533

Client: West San Bernardino County WD
P.O. Box 920
Rialto, CA 92376-0920

Project No.:
Contact: Ken Sikorski
Phone: (909)875-1804

Project:

Sampled By: SPIK
Date Sampled: 02/24/03 14:00:00
Date Received: 02/24/03 15:45:00
Date Started: 02/25/03
Date Completed: 03/03/03
Date Reported: 03/30/03 19:30:47

Lab Contact:
Job No.:
COC Log No.:
Lab ID No.: M31533-1A
Batch No.:
Instrument ID: VAR
Analyst ID: ORGSTAFF
Matrix: WATER

Sample: WELL 34

Little Basin

Analyte		CAS No.	Results	DLR	Method
Boron (B)	ug/L	7440-42-8	ND	100	EPA 200.7
Chromium (+6)	ug/L	N/A	3.0	1.0	EPA 218.6
Perchlorate (ClO4)	ug/L	N/A	ND	4.0	EPA 314.0
Vanadium (V)	ug/L	7440-62-2	ND	3.0	EPA 200.9

ND = Not detected at or above indicated DLR; Detection Limit for Reporting

Manager: _____

Director: _____

Analysis Report: Lab Job M30225

Client: West San Bernardino County WD
P.O. Box 920
Rialto, CA 92376-0920

Project No.:
Contact: Ken Sikorski
Phone: (909)875-1804

Project:

Sampled By: T SPIK
Date Sampled: 01/09/03 14:15:00
Date Received: 01/09/03 16:05:00
Date Started: 01/09/03
Date Completed: 01/14/03
Date Reported: 03/02/03 17:05:35

Lab Contact:
Job No.:
COC Log No.:
Lab ID No.: M30225-8A
Batch No.:
Instrument ID: VAR
Analyst ID: ORGSTAFF
Matrix: WATER

Sample: WELL 36 *Lytle Basin*

Analyte		CAS No.	Results	DLR	Method
Arsenic (As)	ug/L	7440-38-2	2.3	2.0	SM 3113-B
Boron (B)	ug/L	7440-42-8	ND	100	EPA 200.7
Chromium (+6)	ug/L	N/A	1.7	1.0	EPA 218.6
Perchlorate (ClO4)	ug/L	N/A	ND	4.0	EPA 314.0
Vanadium (V)	ug/L	7440-62-2	4.6	3.0	EPA 200.9

ND = Not detected at or above indicated DLR; Detection Limit for Reporting

Manager: _____

Director: _____

Analysis Report: Lab Job M30228

Client: West San Bernardino County WD
 P.O. Box 920
 Rialto, CA 92376-0920

Project No.:
 Contact: Ken Sikorski
 Phone: (909)875-1804

Project:

Sampled By: SPIK
 Date Sampled: 01/10/03 14:00:00
 Date Received: 01/10/03 14:50:00
 Date Started: 01/10/03
 Date Completed: 01/14/03
 Date Reported: 03/02/03 17:09:17

Lab Contact:
 Job No.:
 COC Log No.:
 Lab ID No.: M30228-2A
 Batch No.:
 Instrument ID: VAR
 Analyst ID: ORGSTAFF
 Matrix: WATER

Sample: WELL 37

Chino Basin

Analyte		CAS No.	Results	DLR	Method
Boron (B)	ug/L	7440-42-8	ND	100	EPA 200.7
Chromium (+6)	ug/L	N/A	2.9	1.0	EPA 218.6
Perchlorate (ClO4)	ug/L	N/A	7.5	4.0	EPA 314.0
Source Temperature	C	N/A	16.7	0.0	
Vanadium (V)	ug/L	7440-62-2	8.6	3.0	EPA 200.9
Apparent Color (Unfiltered)	Units	N/A	ND	3.0	SM 2120B
Odor Threshold at 60 C	TON	N/A	1	1.0	EPA 140.1
Lab Turbidity	NTU	N/A	2.5	0.10	EPA 180.1

ND = Not detected at or above indicated DLR; Detection Limit for Reporting

Manager: _____

Director: _____

Analysis Report: Lab Job M30225

Client: West San Bernardino County WD
 P.O. Box 920
 Rialto, CA 92376-0920

Project No.:
 Contact: Ken Sikorski
 Phone: (909)875-1804

Project:

Sampled By: T SPIK
 Date Sampled: 01/09/03 15:30:00
 Date Received: 01/09/03 16:05:00
 Date Started: 01/09/03
 Date Completed: 01/14/03
 Date Reported: 03/02/03 17:05:35

Lab Contact:
 Job No.:
 COC Log No.:
 Lab ID No.: M30225-4A
 Batch No.:
 Instrument ID: VAR
 Analyst ID: ORGSTAFF
 Matrix: WATER

Sample: WELL 41 TRIPLICATE

North Riverside

Analyte		CAS No.	Results	DLR	Method
Boron (B)	ug/L	7440-42-8	ND	100	EPA 200.7
Chromium (+6)	ug/L	N/A	1.7	1.0	EPA 218.6
Nitrate (NO3)	mg/L	N/A	22	2.0	EPA 300.0
Perchlorate (ClO4)	ug/L	N/A	4.9	4.0	EPA 314.0
Source Temperature	C	N/A	18.9	0.0	
Vanadium (V)	ug/L	7440-62-2	7.7	3.0	EPA 200.9
Apparent Color (Unfiltered)	Units	N/A	ND	3.0	SM 2120B
Odor Threshold at 60 C	TON	N/A	1	1.0	EPA 140.1
Lab Turbidity	NTU	N/A	0.5	0.10	EPA 180.1

ND = Not detected at or above indicated DLR; Detection Limit for Reporting

Manager: _____

Director: _____

Analysis Report: Lab Job M2A767

Client: West San Bernardino County WD
 P.O. Box 920
 Rialto, CA 92376-0920

Project No.:
 Contact: Ken Sikorski
 Phone: (909)875-1804

Project: UCMR

Lab Contact:
 Job No.:
 COC Log No.:
 Lab ID No.: M2A767-2A
 Batch No.:
 Instrument ID: VAR
 Analyst ID: ORGSTAFF
 Matrix: WATER

Sampled By: SPIK
 Date Sampled: 12/12/02 13:00:00
 Date Received: 12/12/02 14:15:00
 Date Started: 12/13/02
 Date Completed: 12/17/02
 Date Reported: 03/02/03 17:30:26

Sample: WELL 42 North Riverside

Analyte		CAS No.	Results	DLR	Method
Arsenic (As)	ug/L	7440-38-2	ND	2.0	SM 3113-B
Boron (B)	ug/L	7440-42-8	ND	100	EPA 200.7
Chromium (+6)	ug/L	N/A	1.9	1.0	EPA 218.6
Nitrate (NO3)	mg/L	N/A	23	2.0	EPA 300.0
Perchlorate (ClO4)	ug/L	N/A	ND	4.0	EPA 314.0
Vanadium (V)	ug/L	7440-62-2	5.9	3.0	EPA 200.9

ND = Not detected at or above indicated DLR; Detection Limit for Reporting

Manager: _____

Director: _____