

# **Proposed Rule 1179.1**

## **NOx Emission Reductions from Combustion Equipment at Publicly Owned Treatment Works Facilities**

Working Group Meeting #4

Date: February 12, 2020

Conference call #: 1-866-705-2554

Passcode: 220103

# Agenda

- Summary of last working group meeting
- Public Comments
- Applicability
- BARCT assessment
  - Microturbines
  - Boilers  $\leq 2$  mmbtu/hr
  - Boilers  $> 2$  mmbtu/hr
  - Turbines



Photo courtesy of [www.ocsd.com/Home/ShowImage?id=1700&t=636274946915770000](http://www.ocsd.com/Home/ShowImage?id=1700&t=636274946915770000)

# Summary of Last Working Group Meeting

- Applicability
  - Engine applicability and associated fees with including engines
    - Engine survey
  - Boilers, turbines, and microturbines located at POTWs that fire either natural gas and/or digester gas
- Technology Assessment
  - Control technologies and gas treatment systems
  - Application of technologies
  - Feasibility of NO<sub>x</sub> emission levels with technologies
  - Proposed initial NO<sub>x</sub> limits for boilers >2 mmbtu/hr and turbines
- Listed sources for obtaining cost information

# Comments Made at Working Group Meeting #3

## Stakeholders commented:

Fees for permit revisions for engines can be waived



Future working group meeting should focus on costs and cost effectiveness



One facility is experiencing damage to burners on their digester gas boilers



## South Coast AQMD responses:

South Coast cannot guarantee that the Governing Board will waive fees

Working group meeting #4 will focus on costs and cost effectiveness

Issue appears to be specific to one facility  
Seeking input from other facilities

# Comments Made at Working Group Meeting #3 (continued)

Stakeholders commented:

South Coast AQMD responses:

Boiler results did not include results at low and high loads (only average loads presented)



Staff will present source test results for all loads that boilers were tested at

Do not agree that the Biogas Toolkit is an accurate source for cost information



Biogas toolkit information will not be used to obtain cost information. Costs for gas treatment systems will rely on information from facilities and suppliers.

**Applicability**

# Engines – Survey Results

- Staff sent a survey out on December 12, 2019 to all POTWs with engines to determine the consensus of including engines in the applicability of PR 1179.1
- 8 agencies (12 facilities) had a biogas or natural gas engine
  - 6 agencies are in favor of including only biogas engines
  - 1 agency that has 5 natural gas engines is in favor of including engines
  - 1 agency that has one natural gas engine is not in favor of including engines

Dear Stakeholder:

South Coast AQMD is currently working on Proposed Rule (PR) 1179.1 – NOx Emission Reductions from Combustion Equipment at Publicly Owned Treatment Works Facilities (POTWs). Proposed applicability for this rule includes boilers, turbines, and digester gas-fired microturbines.

During the rule development process for PR 1179.1, some stakeholders have requested that engines located at POTWs be included in PR 1179.1 instead of Rule 1110.2– Emissions from Gaseous- and Liquid-Fueled Engines. Including engines in PR 1179.1 would address most major combustion equipment used at POTWs in one rule. Since Rule 1110.2 was amended on November 1, 2019, staff is not proposing changes to the emission limits or monitoring, reporting, or recordkeeping requirements.

Staff is seeking your input regarding including engines at POTWs in PR 1179.1 or Rule 1110.2. If engines located at POTWs remain subject to Rule 1110.2, no fees would be incurred by facilities. If engines located at POTWs are to be included in PR 1179.1, the following would be required:

- 1) A permit application for each engine;
- 2) An I&M Plan for each facility; and
- 3) A Title V permit revision for each facility under the Title V program.

Submission of permit applications may be categorized as an administrative change, change of condition, or alteration or modification. Staff does not anticipate the process of updating references from Rule 1110.2 to Rule 1179.1 to result in an increase of emissions and therefore a permit alteration or modification would not be required. The following summarizes the administrative changes and changes of conditions:

- Administrative changes are changes in the permit description or changes in permit conditions to reflect actual operating conditions – they do not require an engineering evaluation and do not cause a change in emissions.
- Changes of conditions are changes of current permit conditions that do not result in an increase of emissions.

Rule 301 – Permitting and Associated Fees contains the fee schedule for the issuance of permits. See Table I and Table II for a description of potential applicable fees and examples.

South Coast AQMD's standard practice is to require new permit application submittals, and payment of associated fees, to ensure permits reference the correct rule(s) and requirements. Some stakeholders have commented that the fee should be waived; this is at the discretion of the Governing Board and staff cannot guarantee that fees will be waived.

Inclusion of engines is voluntary, therefore staff requests that you please respond with:

Yes, include engines in the applicability of PR 1179.1 even if there may be fees for permit changes

No, do not include engines in the applicability of PR 1179.1

Please submit your responses by email to [mgamoning@aqmd.gov](mailto:mgamoning@aqmd.gov) no later than January 10, 2020.

Thank you,

Melissa Gamoning

**Table I: Current Fiscal Year Permit Application Processing Fees**

Change	New Title V	Title V
Engine Permit - administrative change required (per engine)	\$962.75	\$1,208.41
Engine Permit - change of conditions required (per engine)	\$4,518.40	\$5,412.49
I & M Plan (per plant/per facility)	\$725.00	\$909.25
Title V Revision (per facility)	N/A	\$1,518.28

**Table II: Examples of Fees for Non-Title V and Title V Facilities**

Permit or Plan Application	Non-Title V	Title V
Engine Permit (1 engine)	\$962.75 - \$4,518.40	\$1,208.41 - \$5,412.49
I & M Plan (per facility)	\$725.00	\$909.25
Title V Revision (per facility)	N/A	\$1,518.28
<b>Total Per Facility**</b>	<b>\$1,688.00 - \$5,243.00*</b>	<b>\$3,635.94 - \$7,840.04*</b>

\* Low and estimate maximum fee for administrative change and high and estimate maximum fee for change of condition.  
\*\* Estimated fees for regulatory - other non-Title V and other combustion equipment subject to PR 1179.1.

# Staff Recommendation for Engines

## ○ Natural gas engines

- 4 out of 5 facilities with natural gas engines responded that they prefer that natural gas engines remain in Rule 1110.2
- Staff recommendation: Natural gas engines will remain in Rule 1110.2

## ○ Biogas engines

- All facilities with biogas engines responded that they prefer that biogas engines be included in Proposed Rule 1179.1
- Staff recommendation:
  - Include biogas engines in Proposed Rule 1179.1
  - Provisions in Rule 1110.2 (emission limits, averaging times, monitoring, reporting, and recordkeeping requirements) will be incorporated in Proposed Rule 1179.1
  - Considering implementation timeframe to revise permit – possibly 2 to 3 years



# BARCT Assessment

# BARCT Assessment – Small boilers $\leq 2$ mmbtu/hr and Microturbines

- Previous working group meetings focused on the technology assessment and initial NOx emission limits for boilers  $> 2$  mmbtu/hr and turbines
- Presenting BARCT assessment for microturbines
  - Technology assessment
  - Initial NOx emission limit
  - Cost-Effectiveness
  - Propose NOx BARCT emission limits
- Beginning BARCT assessment for small boilers  $\leq 2$  mmbtu/hr

# BARCT Assessment – Boilers > 2 mmbtu/hr and Turbines

- Previous working group meetings focused on the technology assessment
  - Low NOx burners, SCR, and gas treatment
- Proposed initial NOx emission limits
  - Boilers retrofit with low NOx burner
  - Turbines retrofit with SCR and implementing gas treatment
- Continuing with BARCT assessment
  - Technology assessment and propose initial NOx emission limit
    - Boilers retrofit with SCR
    - Turbine replacement
  - Cost-effectiveness and propose NOx BARCT emission limits

# Progress of BARCT Assessment

Equipment Category	Assessment of South Coast AQMD Regulatory Requirements	Assessment of Emission Limits for Existing Units	Other Regulatory Requirements	Assessment of Pollution Control Technologies	Initial BARCT Emission Limits and Other Considerations	Cost-Effectiveness Analysis	BARCT Emission Limits
Microturbines							
Boilers $\leq 2$ mmbtu/hr	✓						
Boilers $> 2$ mmbtu/hr	✓	✓	✓	✓	✓		
Turbines	✓	✓	✓	✓	✓		

# BARCT Analysis for Microturbines and Boilers $\leq 2$ mmbtu/hr

## Microturbines (Digester Gas)

- A microturbine is a turbine that is  $< 0.3$  MW
- Currently no rule for microturbines at South Coast AQMD
- Rule 219 allows microturbines  $\leq 3.5$  mmbtu/hr (total output  $< 2$  MW) to be exempt from permitting provided that a filing pursuant to Rule 222 is submitted; and:
  - Microturbines were in operation prior to May 3, 2013; or
  - Microturbines were certified by the state of California at time of manufacture

# Microturbine Universe

Two facilities have a total of 10 microturbines

## Facility 1

- Five 0.03 MW turbines
- 100% digester gas fired
- Exempt from permitting – in operation prior to May 3, 2013

## Facility 2

- Five 0.2 MW turbines
- Permitted to fire digester gas or a blend of digester gas and natural gas
- Not yet in commission


# Microturbines Technology Assessment

- Limited source test information from facilities and supplier
  - 1 source test result of 1.25 ppm
- Supplier can guarantee 9 ppm with proper maintenance and gas treatment
  - 9 ppm achievable with varying loads and HHV
- Gas treatment required for digester gas use
  - Published limit for siloxanes is < 5 ppb (real operations show that higher levels are permissible)
- Control technology
  - Uses a lean premix
  - Addition of SCR difficult due to low exhaust temperature



# Initial NOx Limit for Microturbines

Proposed limit for microturbines that fire digester gas or a blended fuel with digester gas



Turbines < 0.3 MW	Permitted at 9 ppm	1.25 ppm	No known rule limits or permitted digester gas microturbines	9 ppm	9 ppm	9 ppm (Units in operation meeting limit)
-------------------	--------------------	----------	--	-------	-------	---

Cost-effectiveness analysis not conducted since existing sources are meeting the Proposed BARCT NOx Limit


## Boilers $\leq$ 2 mmbtu/hr – Digester Gas

- Currently no rule at South Coast AQMD for boilers  $\leq$  2 mmbtu/hr that fire digester gas
- 12 boilers that range from 0.75 mmbtu/hr – 1.95 mmbtu/hr
  - 10 permitted at 30 ppm
  - 2 permitted at 6 lbs/day
- Staff is assessing the differences between boilers greater than and less than 2 mmbtu/hr
  - Conducting technology assessment to understand if burners that can meet 9 ppm are available for boilers  $\leq$  2 mmbtu/hr

# Cost-Effectiveness Methodology and Assumptions

# Overview

- Cost-effectiveness analysis is conducted on the initial BARCT emission limit
- Cost-effectiveness is the cost (capital plus annual operating costs) over the emission reductions for the life of the equipment
- Staff uses the 2016 AQMP cost-effectiveness threshold of \$50,000 per ton of NOx reduced as guidance for establishing the BARCT limit



# BARCT

California  
H&SC  
§40406  
defines  
BARCT as:

“...an emission limitation that is based on the maximum degree of reduction achievable, taking into account environmental, energy, and economic impacts by each class or category of source.”

- Includes a technology assessment and cost-effectiveness analysis
- Applicable to equipment retrofits and replacement



# Cost-Effectiveness Calculation

- Threshold is \$50,000/ton NOx reduced
- Calculated using Discounted Cash Flow Method
  - Cost Effectiveness = Present Value / Emissions Reduction Over Equipment Life
  - Present Value = Capital Cost + (Annual Operating Costs \* Present Value Formula)
  - Present Value Formula =  $(1 - 1/(1 + r)^n) / r$ 
    - $r = (i - f) / (1 + f)$
    - $i$  = nominal interest rate
    - $f$  = inflation rate

# Elements Included in Capital and Annual Operating Costs

## Capital Costs

- Equipment needed to achieve the initial BARCT limit
- Installation (includes construction)

## Annual Costs

- Labor
- Maintenance
- Electricity
- Catalyst (turbine only)
- Reagent (turbine only)
- Gas treatment media (turbine only)
- Testing

# Other Cost Considerations

## Stranded Assets

- Accounts for costs associated with the replacement of equipment before the equipment life
  - Equipment age based on either the permitted or installation date
- Cost analysis accounted for stranded assets for new equipment replacements
- Additional cost calculated by:
  - $Stranded\ Asset\ Cost = \left( \frac{Equipment\ Life - Existing\ Equipment\ Age}{Equipment\ Life} \right) * (Existing\ Equipment\ Cost)$
  - $Total\ New\ Equipment\ Cost = (New\ Equipment\ Cost) + (Stranded\ Asset\ Cost)$

## Nominal Interest Rate

- 4%



# Other Cost Considerations (*continued*)

Updated Slide

## Equipment Life


- Burners = 15 years
- Turbines = 25 years
- SCR = 25 years
- Gas treatment system = 25 years

## Equipment Replacement

- Equipment replacement is normal component of business operations
  - Replacing equipment after equipment life is not expected to add any additional cost
  - No additional operating & maintenance costs for replacing equipment with similar equipment

# Estimated Emission Reductions

- Emission reductions calculated over same timeframe as equipment life
- Reductions only calculated for units with source test results or permit limits above the initial BARCT limits



# Cost-Effectiveness Analysis

# Implementation Approach for Retrofit or Replacement

Updated Slide

## Overall Goal

- Apply emission limit to equipment via the most cost-effective schedule
- Staff aimed to reduce stranded asset costs and only require replacement when cost-effective to do so

## Two Compliance Scenarios

1. Fixed-Date: Emission limit effective at a set point in time
2. Phase-in: Emission limit effective upon replacement

# Proposed Compliance and Cost-Effectiveness Approach

Updated Slide

Fixed-Date Approach  
Comply by fixed-date

- Emission limit effective on a fixed-date

Phase-in Approach  
Comply upon  
replacement


- Emission limit effective when burner or unit is replaced

- Evaluated cost-effectiveness for all units
- Considerations for a fixed-date or a phase-in approach are based on:
  - Average cost-effectiveness
  - Financial challenges for essential public services
  - Operation and maintenance of equipment

**Boilers > 2 mmbtu/hr**

# Source Test Results for Boilers Firing Digester Gas

- Stakeholders commented that all boiler source test results were not represented for all loads in previous working group meeting
- Analyzed all source test results
  - Low, mid, high loads are shown respectively\*
  - 9 out of 22 boilers meet 9 ppm for all their source test results
  - 6 boilers meeting NOx emissions as low as 7 ppm
    - Using new and retrofit burners



\* Some boilers were only tested at mid loads. One boiler was tested at low and mid load.

# Cost-Effectiveness of NOx Limit of 9 ppm (Retrofit Boiler with Low NOx Burners)

Updated Slide

- Cost-effectiveness excluded units that already meet 9 ppm
- Average cost-effectiveness >>\$50,000 per ton of NOx reduced
  - No capital and annual cost increase assumed to implement burner that can meet 9 ppm
  - Associated costs solely from stranded assets
- It is not cost-effective to retrofit boilers with a burner that can meet 9 ppm if existing burner operations started less than 15 years ago

Staff recommendation: Meet 9 ppm at burner replacement



# Cost-Effectiveness of NO<sub>x</sub> Limit of 5 ppm (Retrofit Boilers $\geq$ 20 mmbtu/hr with SCR)

Updated Slide

- Retrofitting boilers with SCR was analyzed for an initial NO<sub>x</sub> limit of 5 ppm that was determined feasible in the Rule 1146 series rulemaking
  - $> 2$  mmbtu/hr boiler universe ranges from 2.52 mmbtu/hr – 63.5 mmbtu/hr
- Cost-effectiveness was calculated for boilers  $\geq 20$  mmbtu/hr that do not meet 5 ppm
  - Average cost-effectiveness is over \$1 million per ton of NO<sub>x</sub> reduced<sup>◇</sup> and exceeds the \$50,000 per ton of NO<sub>x</sub> reduced threshold

## Staff recommendation:

- Not cost-effective to retrofit boilers  $\geq 20$  mmbtu/hr to meet 5 ppm
- Boilers  $\geq 20$  mmbtu/hr to meet 9 ppm at burner replacement

<sup>◇</sup> SCR requires a gas clean up system. Cost of gas clean up was not included in the cost-effectiveness for SCR retrofits.




**Turbines**

# New Turbine Technology Assessment

- Turbines manufactured after year 2000 are in the 4-25 ppm range when firing natural gas
- Use of digester gas may affect NOx emissions and turbine suppliers warranty higher NOx levels for biogas than natural gas
- Turbine performance in real world applications:
  - 10 turbines in use at landfills without SCR
    - Source test results that range 3.1 ppm – 7.6 ppm
    - Gas treated prior to combustion in turbine
- Staff proposes that initial limits for turbines at landfills can apply to new turbines at POTWs
  - Initial NOx limit = 12.5 ppm

# Initial NOx Limits for Turbine Replacement



BARCT Assessment Results	Only permit limits apply (12.5 – 25ppm)	< 10 ppm (landfill units)	3 – 15 ppm	< 10–25 ppm	12.5 ppm	Need to conduct cost-effectiveness on initial BARCT NOx limit
--------------------------	---	---------------------------	------------	-------------	----------	---

Emissions from this category are the largest in the POTW universe.  
 Total NOx emission for 6 digester turbines is 0.25 tpd

Staff will continue to explore turbine replacement options

# NOx Limits To Be Evaluated

- Cost-effectiveness evaluated for three NOx limits that can be achieved by different methods

## SCR + gas treatment

Reduce NOx emissions to  
2.5 ppm

Based on technology  
assessment presented last  
working group meeting

## Water injection

Reduce NOx emissions to  
18.8 ppm

Based on facility claim  
during Rule 1134  
rulemaking

## Replacement

Reduce NOx emissions to  
12.5 ppm

Based on technology  
assessment – presented in  
this working group meeting

# Obtaining Costs

- Staff obtained costs from facilities, suppliers, and cost estimating tools

## SCR

- Facilities
- EPA Cost Manual Spreadsheet
- Engineering consultants
- Catalyst supplier

## Gas Treatment

- Facilities
- Gas treatment supplier

## Water Injection

- Facility
- Demineralized water supplier

## Turbine Replacement

- Facility
- EPA Manual for CHP Technologies

# SCR Costs

## ○ Assumptions for EPA Cost Manual for SCR and supplier estimates:

- HHV = 665 Btu/scf
- Number of days operating = 365
- Inlet NO<sub>x</sub> = 22 ppm
- Removal efficiency = 90%
- Operating life of catalyst = 24,000 hours
- Equipment life = 25 years
- Design = 5 ppm NH<sub>3</sub> slip (19% aqueous)
- Inlet temperature = 866F
- Electricity = \$0.19/kwh - \$0.25/kwh


Source	Capital Cost	Annual Costs
EPA Cost Manual for SCR	\$8.3 million (3 SCRs)	\$1.2 million (3 SCRs)
Supplier A	\$8.0 million (3 SCRs)	\$489,500 (3 SCRs)
Supplier B	\$2.5 million* (3 SCRs)	\$450,000 (3 SCRs)
Rule 1110.2 staff report	\$1.4 million-\$6.6 million (3 SCRs)	EPA Cost Manual
Facility A	Unavailable	\$38,000 (3 SCRs) new, no catalyst replacement
Facility B	Unavailable	\$48,000 (5 SCRs) new, no catalyst replacement
Average cost for 3 SCRs	\$7.6 million	\$458,500

\* Not included in average cost.

^ Average costs adds \$33,300/year for Facility A and Facility B for catalyst costs

# Gas Treatment Costs – Annual


- Obtained annual costs from 8 facilities
  - All costs obtained from facilities that use SCR
- Siloxane levels for these facilities range from 4.4 ppmv to 15 ppmv
- Gas treatment systems designed to remove siloxane levels to less than <100 ppb
  - One facility treated digester gas to pipeline quality gas – has highest operating costs





# Gas Treatment Costs – Capital

- Obtained capital costs from 3 facilities
- Obtained equipment only costs from one supplier
- Costs assume a gas treatment system that will achieve <100 ppb siloxane level with inlet siloxane levels at <10 ppm



# Costs for Increasing Water Injection

- Facility has stated that they can meet 18.8 ppm with doubling the amount of injected demineralized water
  - Increase of 5,000 – 8,000 gallons per turbine per day
- Facility estimated that the cost of demineralized water is about 10x the cost of potable water
- Staff received cost estimate from supplier for 24,000 gallons per day to meet the needs of 3 turbines

Source	Cost of Demineralized Water	Annual Cost per Turbine
Facility	\$0.07 per gallon (10x cost of regular water)	\$204,400
Demineralized water supplier	\$0.0281 per gallon	\$82,052

# Costs for Replacement

- Staff obtained costs for new turbines from an EPA publication and one landfill facility

Source	Capital Cost	Annual Costs
EPA Catalog of CHP Technologies	\$1.2 – \$1.5 million/MW	\$0.0092 - \$0.0093/kWh
Facility A	\$8.7 million (3 turbines) \$21 million (installation + CEMS)	\$100,000 per turbine

# Cost-Effectiveness to Meet 2.5 ppm with SCR + Gas Treatment

Retrofit with SCR +  
Implement Gas Treatment

- Cost-effectiveness to retrofit three existing turbines with SCR and implement gas treatment technology that processes 6000 scfm of digester gas

System	Capital Cost	O&M Cost	Emission Reductions (25 years)	Cost-effectiveness (\$/ton of NOx reduced)
Gas treatment	\$26,250,000	\$250,000	1,480 tons	\$30,400
SCR	\$7.6 million	\$470,000		

# Cost-Effectiveness to Meet 18.8 ppm with Increased Water Injection

Increase Water Injection

- Cost-effectiveness to increase water injection rates on existing turbines

Source	Cost of Demineralized Water	Annual Cost per Turbine	Emission Reductions (25 years)	Cost-effectiveness for 3 Turbines (\$/per ton of NOx reduced)
Facility	\$0.07 per gallon (10x cost of regular water)	\$204,400	239 tons	\$40,050
Demineralized water supplier	\$0.0281 per gallon	\$82,052		\$16,077

Average Cost Effectiveness  
\$28,064

# Cost-Effectiveness Analysis to Meet 12.5 ppm with Turbine Replacement

Replacement

- Cost-effectiveness to replace 3 turbines with 6 smaller turbines that can meet 12.5 ppm
  - Gas treatment may not be required – lower levels of gas treatment than that required for SCR may be permissible

System	Capital Cost	O&M Cost	Emission Reductions (25 years)	Cost-effectiveness (\$/ton of NOx reduced)
New Turbines	\$45 million	\$600,000	600 tons	\$90,500

# BARCT Analysis Summary

New Slide

Assessment of South Coast AQMD Regulatory Requirements

Assessment of Emission Limits for Existing Units

Other Regulatory Requirements

Assessment of Pollution Control Technologies


Initial BARCT Emission Limits and Other Considerations

Cost-Effectiveness Analysis

BARCT Emission Limits

	Assessment of South Coast AQMD Regulatory Requirements	Assessment of Emission Limits for Existing Units	Other Regulatory Requirements	Assessment of Pollution Control Technologies	Initial BARCT Emission Limits and Other Considerations	Cost-Effectiveness Analysis	BARCT Emission Limits
NOx Limit 18.8 ppm (water injection)	18.8 – 25 ppm (permit limits)	2.5 – 22 ppm	3 – 15 ppm	< 2.5 ppm	2.5 ppm	< \$50,000 per ton of NOx reduced	18.8 ppm
NOx Limit 2.5 ppm (SCR)							2.5 ppm (at replacement)

# Rulemaking Schedule





# Contacts

## **Melissa Gamoning**

Assistant Air Quality Specialist

[mgamoning@aqmd.gov](mailto:mgamoning@aqmd.gov)

909-396-3115

## **Kevin Orellana**

Program Supervisor

[korellana@aqmd.gov](mailto:korellana@aqmd.gov)

909-396-3492

## **Mike Morris**

Planning and Rules Manager

[mmorris@aqmd.gov](mailto:mmorris@aqmd.gov)

909-396-3282

To receive e-mail notifications for Rule 1179.1 - NOx Emission Reductions from Combustion Equipment at Publicly Owned Treatment Works Facilities, sign up at: [www.aqmd.gov/sign-up](http://www.aqmd.gov/sign-up)